

STATEMENT OF WORK

SOW-01-837-1- 07710A/B-2/1

FOR THE

AIR CONDITIONER, A/E 32C-39, 54,000 BTU/HR

NSN: 4120-00-323-7780 and 4120-01-150-8112

TAMCN: B0011

ID# 07710A and 07710B

11 JANUARY 00

TABLE OF CONTENTS

<u>Section and Reading</u>	<u>Page</u>
1.0 Scope	1
1.1 Background	1
2.0 Applicable Documents	1
2.1 Military Standards	1
2.2 Other Government Documents and Publications	1
2.3 Industry Standards	2
3.0 Requirements	2
3.1 General Tasks	2
3.2 Detail Tasks	3
3.2.1 Phase I - Pre-Induction	3
3.2.2 Phase II - IROAN	3
3.2.3 Phase III - Inspection, Testing and Acceptance	3
3.2.4 Phase IV - Packaging, Handling, Storage and Transportation (PHS&T)	4
3.3 Configuration Control	4
3.4 Electrostatic Discharge (ESD) Control Program	4
3.5 Quality Assurance Provisions	4
3.6 Acceptance	5
3.7 Government Furnished Equipment Accountability (GFE)/Government Furnished Material (GFM)	5
3.8 Contractor Furnished Materiel (CFM)	5
3.9 Rejection	5
Appendix A - Air Conditioner Pre-Induction Inspection Checklist	A-1

STATEMENT OF WORK FOR THE
AIR CONDITIONER, A/E 32C - 39, 54,000 BTU/HR
Inspect Repair Only As Necessary (IROAN)
4120-00-323-7780 and 4120-01-150-8112

1.0 SCOPE. This Statement of Work (SOW) establishes and sets forth tasks and identifies the work efforts that shall be performed by the Contractor in the IROAN effort of the AIR CONDITIONER, 54,000 BTU/HR, hereafter referred to as the Air Conditioner. This document contains requirements to restore the Air Conditioner to Condition Code "A." Condition Code A is defined as "serviceable/issuable without qualification, new, used, repaired or reconditioned materiel which is serviceable and issuable to all customers without limitation or restriction, including materiel with more than 6 months shelf-life remaining." National Stock Number (NSN) 4120-01-150-8112 and 4120-00-323-7780 shall be known as the Air Conditioner.

1.1 Background. IROAN is defined as "That maintenance technique which determines the minimum repairs necessary to restore equipment components or assemblies to prescribed maintenance serviceability standards by utilizing all available diagnostic equipment and test procedures in order to minimize disassembly and parts replacement."

2.0 APPLICABLE DOCUMENTS. The following documents form a part of this SOW to the extent specified. Unless otherwise specified, the issues of these documents are those listed in the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto which is in effect on the date of solicitation. In the event of conflict between the documents referenced herein and the contents of this SOW, the contents of this SOW shall be the superseding requirement.

2.1 Military Standards.

MIL-STD-129	DoD Standard Practice for Military Marking
MIL-STD-130	Identification Marking of U.S. Military Property
MIL-STD-2073-1C	DoD Standard Practice for Military Packaging
<u>Military Standards (Guidance Only)</u> .	
MIL-STD-973	Configuration Management

2.2 Other Government Documents and Publications. The issues of those documents cited below shall be used.

T.O. 35E9-163-1	Technical Manual, Operation and Maintenance Instructions W/Changes 1 - 13
T.O. 359-163-1S-5	Supplement to T.O. 35E9-163-1

TM 3080-50	Corrosion Control Procedures Depot Maintenance Activities for Marine Corps Equipment
TM-4750-15/2	Painting and Registration Marking for Marine Corps Combat and Tactical Equipment
DOD 4000.25-M	MIL STRIP Manual
NAVICPINST 4491.2A	Requisitioning of Contractor Furnished Materiel From The Federal Supply System

2.3 Industry Standards.

ANSI/EIA 625	Requirements for handling Electrostatic-Discharge Sensitive ESDS Devices
ANSI/ISO/ASQC Q9002-1994	Quality Systems Model for Quality Assurance in. Production, Installation, and Servicing

Copies of Military Standards and Specifications are available from the DOD Single Stock Point, Defense Automation Production Service Philadelphia, Building 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094, Telephone (215 697-2179 or DSN 442-2179, or <http://www.dodssp.daps.mil>. Copies of other government documents and publications required by contractors in connection with specific SOW requirements shall be obtained through the contracting officer: Commander, Marine Corps Logistics Bases, (Code 891), 814 Radford Blvd., Albany, Georgia 31704-1128, commercial telephone number (912) 439-6753 or DSN 567-6753. Copies of engineering drawings, if applicable, shall be obtained from Life Cycle Management Center, Attn: Code 825-3, 814 Radford Blvd., STE 20320, Albany, GA. 31704-0320, commercial telephone number (912) 439-6410 or DSN 567-6410.

3.0 REQUIREMENTS.

3.1 General Tasks. In fulfilling the specified requirements, the Contractor shall:

- a. Provide materials, labor, equipment, facilities and missing/repair parts, necessary to inspect, diagnose, restore, and test and calibrate the Air Conditioner. Upon completion of IROAN, the subject item shall be Condition Code "A".
- b. Provide all tools and test equipment required to test, inspect, repair and calibrate the Air Conditioner.
- c. Conduct in-process and final on-site testing for witness by a Marine Corps Logistics Bases (MCLB), Albany, representative.

3.2 Detail Tasks. The following tasks describe the different phases for IROAN of the Air Conditioner.

3.2.1 Phase I- Pre-induction. A pre-induction inspection analysis shall be performed for each Air Conditioner using the Contractor Facility's diagnosis, inspection and testing techniques and Air Force manuals T.O. 35E9-163-1 and T.O. 359-163-1S-5 to determine extent of work and parts required. These findings shall be annotated, located, identified, and provided to the government on the Pre-Induction Checklist (Appendix A).

3.2.2 Phase II - IROAN. After pre-induction tests and inspections have been completed, repair of the Air Conditioner shall be accomplished in accordance with this SOW. Deficiencies noted on the Pre-Induction Checklist (Appendix A) during Phase I shall be repaired/replaced. Components or assemblies shall not be disassembled for replacement of parts unless that part has failed, or the component assembly wherein the part is located is disassembled for repair.

a. Pre-Induction Checklist - Information recorded on the pre-induction checklist (Appendix A) shall be used as a guide to repair the Air Conditioner in accordance with this SOW.

b. Data Plate - Each repaired Air Conditioner shall have an IROAN data plate affixed to the main unit in close proximity to the existing data plate. The data plate shall meet the requirements of MIL-STD-130 and TM 4750-15/2.

c. Hardware

(1) Replace broken, unserviceable and/or missing hardware including nuts, bolts, screws, washers, turn lock fasteners, mandatory replacement items, safety, and one-time use items, etc., ect. Unserviceable would include any of the above that failed to function properly.

(2) Ensure proper hardware locking devices are present on all moving mechanical assemblies.

(3) Hardware normally supplied with commercial parts shall be used unless specifically prohibited.

d. Corrosion Control and Painting - Corrosion control preventatives shall be applied per TM-3080-50 and painting shall be accomplished per TM-4750-15/2.

3.2.3 Phase III - Inspection, Testing and Acceptance.

a. Inspection, Testing and Acceptance of the Air Conditioner shall be conducted.

b. The Contractor shall be responsible for conducting required tests and shall ensure all necessary personnel are notified prior to completion of the final acceptance. Acceptance tests shall be held at Contractor's facility.

c. The Contractor shall be responsible for correcting any deficiencies identified during inspection/testing. MCLB Albany, Georgia, (Code 837-1), representatives may require the Contractor to repeat tests or portions thereof, if the original tests fail to demonstrate compliance with this SOW.

d. The operation Tests are to be conducted on each Air Conditioner upon completion of repairs and prior to the equipment being returned to stock.

3.2.4 Phase IV - Packaging, Handling, Storage and Transportation (PHS&T).

a. The contractor shall be responsible for preservation and packaging of items being repaired under the terms of this statement of work. Items scheduled for long term storage or shipment to overseas destinations shall be packaged to the level "A" requirements of MIL-STD-2073-1C, Method 54. Items scheduled for domestic shipment, immediate use or short term storage shall be level "B" requirements.

b. Marking shall be in accordance with MIL-STD-129.

c. The Marine Corps will provide the contractor with the shipping address(es) for delivery of the repaired equipment. The contractor shall be responsible for arranging for shipment to the pre-designated site(s). The Marine Corps will be responsible for transportation costs associated with shipping the equipment to and from the Contractor.

3.3 Configuration Control. The contractor shall apply configuration control procedures to established configuration items. The contractor shall not implement configuration changes to an item's documented performance or design characteristics without receiving prior written authorization. The baseline configuration has been defined by the written procedures or materials contained in manuals, standards, instructions or engineering drawings. If it is necessary to depart from the authorized configuration baseline, the contractor shall submit a Request for Deviation or Request for Waiver using MIL-STD-973 (paragraph 5.4.3 or 5.4.4) as a guide.

3.4 Electrostatic Discharge (ESD) Control Program. The Contractor shall establish, implement and document an ESD control Program following the guidelines provided in EIA-625. ESD protective measures shall be used during manufacturing, handling, inspection test, marking, packaging, storing and transporting ESD sensitive components.

3.5 Quality Assurance Provisions. The Contractor shall provide and maintain a Quality System that as a minimum, adheres to the requirements of ANSI/ISO/ASQC Q9002-1994, Quality System Model for Quality Assurance in Production, Installation, and Servicing. The program shall ensure quality throughout all areas to include design, fabrication, processing, assembly, inspection, test, maintenance, and preparation for delivery and shipping. Unless otherwise specified in the contract, the contractor shall be responsible for performance of all inspection requirements. The Government reserves the right to perform any of the inspections set forth in the contract where such inspections are deemed necessary to assure products and services conform to the prescribed requirements.

3.6 Acceptance. The performance of the Contractor and the quality of work delivered, including all equipment furnished and documentation written or compiled, shall be subject to in-process review and inspection during performance. Inspection may be accomplished in-plant or at any work site or location, and Marine Corps representatives shall be permitted to observe the work or to conduct an inspection. Final inspection and acceptance testing shall be conducted at the Contractor's Facility. Final acceptance shall be conducted on 100 percent of items to verify that the units meet all requirements.

3.7 Government Furnished Equipment (GFE)/Government Furnished Materiel (GFM). GFE is government owned equipment authorized by contract for use by a commercial/Government contractor. It is neither consumed during production nor incorporated into the product. GFM is materiel furnished to a contractor that will be consumed during the course of production or incorporated into the product being manufactured/remanufactured under a contract/statement of work. In the event the Marine Corps does have GFE/GFM requirements the Management Control Activity (MCA/Code 827-2), Marine Corps Logistics Bases, Albany, Georgia, will coordinate required GFE and will maintain a central control on Marine Corps assets in the Contractor's possession. The MCA will forward a GFE Accountability agreement to the Contractor Facility for signature to establish a chain of custody and property responsibilities for the Marine Corps assets.

3.8 Contractor Furnished Materiel (CFM). The Marine Corps has adopted the Navy's procedures regarding Contractor Furnished Materiel (NAVICPINST 4491.21A). In the event that Contractor Furnished Materiel (CFM) is required for repair parts, the contractor shall requisition repair parts through the DoD Supply System. DoD 4000.25-1-M (MILSTRIP), Chapter 11 authorizes contractors to requisition through the DoD Supply System

3.9 Rejection. Failure to comply with any of the specified requirements listed herein shall be reason for rejection by MCLB, Albany, (Code 837-1) representative. The Contractor shall, at no additional cost, correct the deficiencies and repeat the verification.

CONTRACT DATA REQUIREMENTS LIST

(1 Data Item)

Form Approved
OMB No. 1704-0188

The Public reporting burden for this collection of information is authorized to average 110 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302 and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503. Please DO NOT RETURN your form to either of these addresses. Send completed form to the Government issuing Contract Officer for the contract/PR No. listed in block E.

A. CONTRACT LINE ITEM NO.	B. EXHIBIT	C. CATEGORY: TDP _____ TM _____ Other XXX
---------------------------	------------	---

D. SYSTEM/ITEM Air Conditioner A/E 32C-39, 54,000 BTU/HR	E. CONTRACT/PR No.	F. CONTRACTOR
--	--------------------	---------------

1. DATA ITEM No. A001	2. TITLE OF DATA ITEM Request for Waiver (RFW)	3. SUBTITLE Configuration Management
--------------------------	---	---

4. AUTHORITY (Data Acquisition Document No.) DI-CMAN-80641B	5. CONTRACT REFERENCE SOW 3.3	6. REQUIRING OFFICE MARCORLOGBASESALB 825
--	----------------------------------	--

7. DD 250 REQ. LT	9. DIST STATEMENT REQUIRED A	10. FREQUENCY AS REQ	12. DATE OF FIRST SUBMISSION See Blk 16	14. DISTRIBUTION		
8. APP CODE		11. AS OF DATE	13. DATE OF SUBSEQUENT SUBMISSION	a. ADDRESSEE	b. COPIES	
					Draft	FINAL Reg Repro

16. REMARKS Block 4: Contractor format is authorized. Blocks 10 & 12: RFWs shall be submitted to obtain authorization to deliver nonconforming material which does not meet the prescribed configuration documentation. RFWs will be reviewed and disposition determined within 30 calendar days upon receipt by the government. RFWs shall be transmitted via e-mail to the following address: mbmatcomconfigmngmnt@matcom.usmc.mil Distribution Statement A: Approved for public release, distribution is unlimited.	MCLBA 825-2	0	1	0
	15. TOTAL	0	1	0

G. PREPARED BY: <i>Dang</i>	H. DATE 2-3-00	I. APPROVED BY: <i>Herall R Hall</i>	J. DATE 2/8/00
--------------------------------	-------------------	---	-------------------

17. PRICE GROUP

18. ESTIMATED TOTAL PRICE

